



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	Page 1 of 8
afp - 2762	10-May-2012	Number 16 Issue date 16-Jun-2023	30-Apr-2024	

Product designation

QTEC VDAS, Loss of Pressure (LOP) and Rise of Pressure (ROP), pre-engineered foam water spray vehicular fire extinguishing system

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

QTEC Fire Services
5 Buttonwood Place, WILLAWONG, QLD, AUSTRALIA, 4110

Registrant

QTEC Fire Services
5 Buttonwood Place, WILLAWONG, QLD, AUSTRALIA, 4110

Producer

QTEC Fire Services
5 Buttonwood Place, WILLAWONG, QLD, AUSTRALIA, 4110

Conformance criteria and evaluation

The QTEC VDAS, Loss of Pressure (LOP) and Rise of Pressure (ROP), pre-engineered foam water spray vehicular fire extinguishing system has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 5062:2016, 'Fire protection for mobile and transportable equipment'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

1. VDAS Loss of Pressure (LOP) Systems
 - a. The system is designed, installed, operated, and maintained, in accordance with the QTEC Fire Services Pty Ltd, VDAS LOP Design, Installation, and Commissioning Manual Edition 11 (Part number QTB951).
 - b. The fire suppression system is to be only operated between: - 5 °C to 60 °C.
 - c. LOP valve operating pressure range: min 1,350 kPa—max. 1,500 kPa.

(Limitations/conditions of conformance continue)

Issued by

Kaj Loh

Executive Officer – ActivFire Scheme





**To view the rest of the certificate,
kindly request a copy from Geoff Smith at
geoff.smith@qtecfire.com.au**